# Kidde Fire Systems System Component Datasheet


## **Electric Main-to-Reserve Transfer Switch**



Effective: December 2018 K-85-0531 Rev AB

#### FEATURES

- UL Listed, ULC Listed, and FM Approved for use with systems listed in the Table , "COMPATIBILITY," on page 2.
- P/N: 84-802398-000



### MATERIALS

Conduit Box: Steel with Red Enamel Finish Toggle Switch Lever: Bakelite 30 Amps @ 120 Vac

#### COMPATIBILITY

| Series   | DIOM P/N      |
|--|---------------|
| Kidde <sup>®</sup> ECS-500™ System                                 | 06-237585-001 |
| Kidde <sup>®</sup> ECS™ with 3M™ Novec™ 1230 Fire Protection Fluid | 06-236553-001 |
| Kidde <sup>®</sup> ADS™ with 3M™ Novec™ 1230 Fire Protection Fluid | 06-237256-001 |
| Kidde <sup>®</sup> ECS™ with HFC-227ea Agent                       | 06-236115-001 |
| Kidde <sup>®</sup> ADS™ with HFC-227ea Agent                       | 06-236068-001 |
| Kidde <sup>®</sup> High Pressure CO <sub>2</sub>                   | 81-CO2MAN-001 |
| Kidde <sup>®</sup> FE-13™ Modular Engineered Suppression System    | 06-236193-001 |
| Kidde <sup>®</sup> FE-13™ Engineered Suppression System            | 06-236169-002 |

EXPORT INFORMATION (USA) Jurisdiction: EAR Classification: EAR99 This document contains technical data subject to the EAR.

KIDDE is a registered trademark of Kidde-Fenwal, Inc., or its parents, subsidiaries or affiliates.

This literature is provided for informational purposes only. KIDDE-FENWAL, INC. believes this data to be accurate, but it is published and presented without any guarantee or warranty whatsoever. KIDDE-FENWAL, INC. assumes no responsibility for the product's suitability for a particular application. Product features specified are only applicable when the fire suppression system is correctly designed, installed, maintained and serviced by trained, authorized Kidde Fire Systems distributors as per the applicable design, installation, operation, and maintenance manuals. If you need more information on this product, or if you have a particular problem or question, contact: KIDDE-FENWAL, INC., Ashland, MA 01721 USA, Telephone: (508) 881-2000.



2

K-85-0531 Rev AB ©2018 Kidde-Fenwal, Inc. Kidde Fire Systems 400 Main Street Ashland, MA 01721 Ph: 508.881.2000 Fax: 508.881.8920 www.kiddefiresystems.com